



Ref. Certif. No.

CN13986

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**Product
Produit

Low-voltage Fuses (Fuses with fuse-links with blade contacts)

Name and address of the applicant
Nom et adresse du demandeurZHEJIANG MINGRONG ELECTRICAL PROTECTION CO.,LTD
Wei llth Road,Economic Developing Zone,Yueqing Zhejiang CchinaName and address of the manufacturer
Nom et adresse du fabricantZHEJIANG MINGRONG ELECTRICAL PROTECTION CO.,LTD
Wei llth Road,Economic Developing Zone,Yueqing Zhejiang CchinaName and address of the factory
Nome et adresse de l'usineZHEJIANG MINGRONG ELECTRICAL PROTECTION CO.,LTD
Wei llth Road,Economic Developing Zone,Yueqing Zhejiang CchinaNote: When more than one factory, please report on page 2
Note: Lorsque plus d'une usinem, veuillez utiliser la 2^{eme} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principalesfuse-link;Ue:AC500V/690V; In:AC690V:4A、6A、10A、16A、20A、
25A、32A、40A、50A、63A、80A、100A;AC500V:4A、6A、10
A、16A、20A、25A、32A、40A、50A、63A、80A、100A、125
A、160A;Rated breaking capacity:500V/100kA,690V/50kA;Breaking ra
nge and utilization category:gG;fuse-holder:Un:AC690V,In:160A
MROTrademark (if any)
Marque de fabrique (si elle existe)Model / Type Ref.
Ref. De type

RT16-0(NT0);

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{eme} page)**PUBLICATION****EDITION**A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC60269-2-1:2004(see also IEC60269-1:1998)

As shown in the Test Report Ref. No. which forms part
of this CertificateComme indiqué dans le Rapport d'essais numéro de
référence qui constire partie de ce Certificat

C009-CB2009CQC-019343

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification****CHINA QUALITY CERTIFICATION CENTRE**

Date: 2009-05-22

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9,No.188,Nansihuan Xilu, Beijing 100070 P.R.ChinaTel: +86-10-83886666
Fax: +86-10-83886282website
www.cqc.com.cn**CB 0003881**