



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

**Certificate No.:** CE180304006084

**Product** Fuse-switch-disconnectors

**Applicant** Zhejiang Mingrong Electrical Protection Co., Ltd.  
Wei 11th Road, Yueqing Economic Development Zone,  
Zhejiang Province, P.R.China

**Type/Model** MRO.H1(DR1)-400

**Technical data** Uimp:8kV;Ui:1000V;Ith:400A;AC-23B;Ue/  
Ie:AC690V/400A;Iq:50kA;3P; 50/60Hz

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2018CQC0304-009620, the submitted sample(s) of the above item complies with:

**EN 60947-3:2009 + A2:2015**

and fulfills testing requirements of the European Directive:  
**2014/35/EU**

**Valid from:** Dec.26,2018

**Valid until:** Dec.26,2021

President:

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**  
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>