



Ref. Certif. No.

CN14332

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE

Product  
Produit

Low-voltage fuses(Fuses with fuse-links with blade contacts)

Name and address of the applicant  
Nom et adresse du demandeur

ZHEJIANG MINGRONG ELECTRICAL PROTECTION CO.,LTD  
Wei llth Road,Economic Developing Zone,Yueqing Zhejiang Cchina

Name and address of the manufacturer  
Nom et adresse du fabricant

ZHEJIANG MINGRONG ELECTRICAL PROTECTION CO.,LTD  
Wei llth Road,Economic Developing Zone,Yueqing Zhejiang Cchina

Name and address of the factory  
Nome et adresse de l'usine

ZHEJIANG MINGRONG ELECTRICAL PROTECTION CO.,LTD  
Wei llth Road,Economic Developing Zone,Yueqing Zhejiang Cchina

Note: When more than one factory, please report on page 2  
Note: Lorsqueily plus d'une usinem, veuillez utiliser la 2<sup>me</sup> page

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

Fuse-link:Un:AC500V/690V; In:690V:125A、160A、200A、224A、250A、300A、315A、355A、400A;fuse-holder:Un:AC690V;In:400A; Rated breaking Capacity:500V/100kA,690V/50kA; Breaking capacity and utilization category:gG MRO

Trademark (if any)  
Marque de fabrique (si elle existe)

RT16-2(NT2)

Model / Type Ref.  
Ref. De type

Additional information (if necessary may also be reported on page 2)  
Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2<sup>me</sup> page)

PUBLICATION

EDITION

A sample of the product was tested and found to be in conformity with  
Un échantillon de ce produit a été essayé et a été considéré conforme à la

IEC60269-2-1:2004

As shown in the Test Report Ref. No. which forms part of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de référence qui constitre partie de ce Certificat

C009-CB2009CQC-019345

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: 2009-06-24

Signature:

Wang Kejiao